
Air conditioners as a source of bacterial contamination in an indoor environment

Hind M. Khalfallah¹, Omar M. Abukhres^{2*}, Ali F. Hawad¹, Ibrahim A. Mukhtar³, Hussien A. Alrasheed⁴

1. Department of medical laboratory technology, faculty of engineering and technology, university of Sebha, Libya

2. Faculty of dentistry, AljbelAlgharby university, Alzentan, Libya, 3. Faculty of medical technology, university of Tripoli, Tripoli, Libya ,4. Faculty of medicine university of Sebha, Libya

* corresponding author: omarabukhres@yahoo.com

Abstract

The objectives of this study were to assess the bacterial content of air conditioning and indoor air of some hospitals in the south of Libya. This study was conducted in a 2nd of March hospital and Brack general hospital in southern Libya. Samples were collected from indoor air, and from filters, cooling coils, and water drainage basins of air conditioning units in those hospitals. Bacterial colonies were counted and identified characteristics of the bacteria on blood agar and Mc conkey agar, also identified bacterial species. Bacterial numbers in the samples taken from 2nd March hospital formed 56.57% of the total indoor air samples, 79.9% of the total filters samples, 72.07% of the total coils samples, and 54.63% of the total water samples. The bacterial numbers in samples taken from a Brack general hospital contained 43.43% of the total indoor air samples, 20.1% of the total filter samples, 27.93% of the total coils samples, and 45.37% of the total water samples. The bacterial species identified included some species of pathogenic bacteria as *S.aureus*, which existed in the various samples, *K.pneumoniae*, Bacillus and Pseudomonas, those species involved in nosocomial infections.

Conclusion: The occurrence of high bacterial numbers on parts of air-conditioning followed by its spread to the internal environment which constitutes a health risk to people exposed to it especially if this environment is the hospitals where patients with various injuries.

Keywords: air conditioning, hospital, indoor air, pathogenic bacteria.

Introduction

A number of studies by a group of health and environment scientists have shown that indoor air pollutants are a major health hazard in a number of cities, and the world health organization has estimated that 30%

of recently built or recently renovated buildings contain a contaminated air(1). Furthermore, the American society of heating, cooling and air conditioning has indicated that more than 20% of the

residents of these buildings suffer from health problems caused by contaminated indoor environment (1). The health hazard related to residential buildings, or work places such as offices and schools became extremely important factor for community health. The severity and frequency of these problems has increased in 1980's altogether with increased reports about infections described to be connected with insufficient air circulation and caused by air borne contaminants inside these buildings which contain air conditioning units. A number of studies have shown that there is a relationship between contaminated air conditioning units and a health problem known as a building syndrome (2;3). In addition in a number of studies to investigate the relationship between the type of air condition unit and the symptoms related to work places that are common between office workers it has been shown that symptoms such as headache, weakness, upper respiratory tract and mucosal infections are always associated with air conditioned places (4). In one study in Hong Kong for the quality of indoor air in some air conditioned offices has shown that the mechanical air conditioned spaces has a great effect on the microorganisms load i.e. bacteria and fungi in air (5), and that these machines are a habitat for microbial communities and a source for their distribution in the surrounding environment (6). Air conditioning units as described by Muyshoundt and colleagues are a safe place for microbes and subsequently spreading it in to the environment, the same observation was reported by Harrison and co-workers, as they have found that the bacterial count

ranged between 2-960 colony forming unit/ml in a 15 English office contain different air conditioning units and ventilation systems (7; 8). Other studies have reported that the accumulation of dust on the air conditioning filters provided a good environment for microbial growth (9), this was further confirmed by studies on the prevalence of microbes on different components of air conditioning units (10; 11), as these studies have proved that the contaminated air conditioning units provided suitable environment for the microbial growth on the different components of these units such as filters, water tanks etc., as these microbes tend to grow on the biofilm on the surface of the units components (12). A Japanese study has examined the prevalence of bacteria and fungi in the internal parts of the air conditions units before and after cleaning and in the inside air, they concluded that the contaminated internal tubes is a source of spreading of microbes in the internal environment (13). Pathogenic bacteria such as *Legionella* species which is one of the most common bacteria isolated from an indoor environments (14). Another Gram positive and Gram negative bacteria were also isolated from air conditioning units (11). The objectives of this study were to assess the bacterial content of air conditioning and indoor air of some hospitals in the south of Libya.

Material and Methods

This study was conducted in Brack general Hospital and 2nd of March hospital. Samples from these institutions were collected from an indoor air according to the standard method (1). Samples from air condition

parts (filters, cooling coils) were collected by sterile cotton swabs, and samples of water were taken from the drainage basins. Samples were inoculated on Tryptic Soya Agar media as primary cultures. Plates were incubated at 28 °C for 48 hours, after the incubation, and the total viable count of bacterial colonies were performed using standard methods, and selected colony of each type of bacteria as a representative of this type was inoculated on the culture media McConkey agar and Blood Agar. Bacterial isolates were identified by using the standard methods used in the microbiology laboratories of this department.

Results

Bacterial numbers in samples taken from the 2nd of arch hospital ranged between 2-32 cfu/m²/h in air samples average 15.16, which is 56.57% of the total indoor air samples in both hospitals). Bacterial counts on filters ranged between 40-3000 cfu/cm² average 528.71 (79.9% of the total filter samples in both hospitals). Counts on coils ranged from 10 to 2710 cfu/cm² average 466.48 (72.07% of the total coils sample in both hospitals). Water tanks contained between 10 to 11.000 cfu/ml average 3060 (54.63% of the total samples of water in both hospitals). Isolated bacteria were classified on the basis of Gram stain, morphology and culture characteristic, on McConkey Agar and Blood Agar. Table 1. Bacterial counts on samples taken from Brack general hospital ranged between 2-31cfu/m²/h in air samples, average 11.64

(43.43% from the total internal samples in both hospitals). Filters from air conditioning units in the same hospital contained an average of 133cfu/cm² (20.1% from the total filter samples of both hospitals). Bacterial counts on coils ranged between 0-1710, average 180.8cfu/cm² (27.93% from the total coil samples from both hospitals), and averaged between 20-12070 cfu/ml, average 2541.4 in drainage water tanks (45.37% from total samples taken from the drainage water from both hospitals, as shown in table 2 which also shows the average number of bacterial groups classified on the basis of Gram reaction, morphology and culture characteristics on blood and McConkey agar media.

In certain experiments an attempt was made to identify the isolated bacteria, and as shown in table 3, some isolates were identified as *Staphylococcus aureus* and micrococci species, these comprised the largest proportion of the total isolated bacteria from air samples from Brack hospital. Coagulase negative *Staphylococci* species were also isolated from both hospitals. Certain *Bacillus* species were present and isolated from coil samples taken air conditioning units in the 2nd of March hospital. Gram negative bacilli species were also present, these included *Klebsiella pneumoniae* and *Flavobacterium*. Water from the drainage tanks contained certain *Pseudomonas* species.

Table 1: total number (percentage) of colony forming units in samples of 2nd of March hospital

		Water	Cooling coils	Filters	indoor air
Morphologic group	Negative bacilli	(55.11) 1686.43	(28.35) 132.25	(63.88) 337.74	(11.87) 1.8
	Positive bacilli	(2.7) 82.5	(33.54) 156.48	(15.74) 83.23	(33.84) 2.13
	Positive cocci	(42.19) 1291.07	(38.1) 177.74	107.74 (20.38)	(84.29) 8.23
Total		(100) 3060	(100) 466.48	(100) 528.71	(100) 15.16
Blood agar	Hemolytic	(2.73) 83.57	(32.09) 149	(17.39) 91.94	(45.71) 6.93
	Non- hemolytic	(97.29) 2976.42	(67.91) 316.77	(82.61) 436.77	(54.29) 8.23
Total		(100) 3060	(100) 466.48	(100) 528.71	(100) 15.16
McConkey agar	Lactose fermenting	(17.03) 521.07	(1.04) 4.84	(21.96) 116.13	(28.5) 4.32
	Non- Lactose fermenting	(48.65) 1488.57	(98.96) 461.64	320.32 (60.59)	(10.84) .& (0)0
	No growth	(34.32) 1050.35	(0)0	(17.45) 92.26	
	Total	(100) 3060	(100) 466.48	(100) 528.71	(100) 15.16

Table 2: total number (percentage) of colony forming units in samples of Brack general hospital

		Water	Cooling coils	Filters	indoor air
Morphologic group	Negative bacilli	(51.75) 1315.24	(17.04) 30.8	(31.13) 41.4	(3.26) 0.38
	Positive bacilli	(20.94) 532.14	(16.7) 30.2	(28.12) 37.4	(13.4) 1.56
	Positive cocci	(27.31) 694.05	(66.26) 119.8	(40.75) 54.2	(83.34) 9.7
Total		(100) 2541.4	(100) 180.8	(100) 133	(100) 11.64
Blood agar	Hemolytic	(0.8) 20.24	(28.43) 51.5	(36.69) 48.8	(36.6) 4.26
	Non- hemolytic	(99.2) 2521.19	(71.57) 129.4	(63.31) 84.2	(63.4) 7.38
Total		(100) 2541.4	(100) 180.8	(100) 133	(100) 11.64
McConkey agar	Lactose fermenting	(27.43) 697.14	(22.68) 41	(31.73) 42.2	(40.38) 4.7
	Non- Lactose fermenting	(61.3) 1557.86	(77.32) 139.8	(50.07) 66.6	(57.39) 6.68
	No growth	(11.27) 286.43	(0)0	(18.2) 24.2	(2.23) 0.26
	Total	(100) 2541.4	(100) 180.8	(100) 133	(100) 11.64

Table 3 shows the number (percentage) of bacterial species in 2nd of March and Brack general hospitals

water		Cooling coils		Filters		indoor air		
<i>Brack general hospitals</i>	<i>2nd of March</i>	<i>Brack general hospitals</i>	<i>2nd of March</i>	<i>Brack general hospitals</i>	<i>2nd of March</i>	<i>Brack general hospitals</i>	<i>2nd of March</i>	
(1.44) 36.47	790.36 (25.83)	(5.86) 10.6	183.23 (39.28)	(20.15) 26.8	(1.89) 10	(46.39) 5.4	3.42 (22.56)	Coagulase-negative staphylococcus
(0.02) 0.59	(0) 0	(1.81) 3.27	(0.83) 3.85	(15.49) 20.6	(0) 0	(32.13) 3.74	(21.9) 3.32	S.aureus
(27.54) 700	(0.02) 0.71	(15.38) 27.8	(0.14) 0.65	(21.8) 29	(17.57) 92.9	(2.41) 0.28	(10.62)	Micrococcus spp
(29.53) 750	(1.34) 41.07	(12.72) 23	(6.98) 32.58	(0.6) 0.8	(5.55) 29.35	(0) 0	(0) 0	Flavobacterium spp
(3.22) 81.76	(0) 0	(0) 0	(0) 0	(0.45) 0.6	(0) 0	(0) 0	(0) 0	Klebsiella Pneumonia
(2.08) 52.94	(0) 0	(15.04) 27.2	(0) 0	(21.95) 29.2	393.87	(3.78) 44	(0) 0	Bacillus spp
(29.49) 749.41	(2.7) 82.5	(1.18) 2.14	143.58	(11.13) 14.8	(74.5)	(7.9) 92	(0) 0	Non-spore forming bacillus
(5.51) 140	(0) 0	(0) 0	(30.77)	(0) 0	(0.12) 0.65	(0) 0	(7.85) 1.19	Pseudomonas spp
(1.17) 29.73	(1.35) 41.18	(48) 86.79	(1.45) 6.77	(8.42) 11.2	(0) 0	(7.39) 0.86	3.71	Unidentified bacteria
	2104.18 (68.76)		(0) 0 (20.55) 95.82		(0.37) 1.94		(24.47)	
(100) 2541.4	(100) 3060	(100) 180.8	(100) 466.48	(100) 133	(100) 528.71	(100) 11.64	(100) 5.16	total

Discussion

In this study the bacterial contents in an internal air samples and parts of air conditioning units installed at different locations in the 2nd of March hospital in Sebha and Brack general hospital. Results obtained were variable; however, bacteria were isolated from both hospital and from almost all samples tested. Numbers and percentages of bacteria isolated were lower than numbers reported in similar study carried out in Brazil (11), and comparable to a study in Jordon (12). Regarding the type of bacteria isolated in this study Gram positive cocci bacteria were the predominant in both hospitals, and was different than those recorded in a hospital in Brazil were Gram positive bacilli was predominant(11). Three hospitals in India have reported similar finding to this study (13).

Filters and coils contained the highest number of bacteria and reached 3000 cfu/cm² in some samples from the 2nd of March hospitals and 1150 cfu/cm² in

samples from Brack hospital, when compared to numbers recorded in 2005 we find that it quite high(14). This finding suggest that it is a contaminated surface, and probably will act as a source of contamination in the internal air, especially as the air passes through these surfaces during operation hours, and as shown by certain studies these contaminated filters will spread bacteria in the internal environment (15). The isolation of Gram negative bacilli in higher proportions from the 2nd of March hospital (63.88%) in agreement with study reported in 2009(14). Cooling coils are considered as a suitable place for the growth of microbes, as it forms what is known as the biofilm(16;17). Furthermore, it is also shown that microbes growing on the biofilm are more resistance to harsh conditions and certain antimicrobial agents (18;19; 20). The results of this study has indicated that the number of bacterial isolates in the samples collected from the internal air and from air conditioning units

installed in the 2nd of March hospital were more than those isolated from Brack hospital (72.07% and 27.93% of the total samples from both hospitals respectively) , this was probably expected as the Brack hospital is smaller, more recent and deals with fewer patients than Sebha hospital, these factors will help to reduce the contamination as the small size and fewer patients and staff will make it easier to clean and easier to manage and this will subsequently reduce the bacterial contamination.

Drainage water from the drainage tanks contained the higher bacterial numbers as compared to other parts as it reached in some samples to 11000 cfu/ml in the drainage tanks of Sebha hospital and 12070 cfu/ml in samples taken from Brack hospital. These numbers are indicative of contamination as the stagnation of water in the drainage tanks provide suitable condition for the growth of many microbes (17). The prevalence of large numbers of bacteria in the internal environments may allow for the spread of certain bacterial components which can be inhaled and become a source of infection in the respiratory tract and sensitivity (22; 23).

The presence of pathogenic bacteria in the internal environments especially in hospitals or students dormitories is a great risk to those inside these places, as people attending hospitals are in greater risk of the nosocomial infections. *S aureus* isolated from 12.9% from internal air samples collected from Sebha hospital and as it is known that this bacteria is capable of causing disease of variable severity from simple skin and wound infection to more

complicated serious infection. (23). Furthermore, a recent report by the center of disease prevention and control has shown that 18650 persons in the united states of America died by methicilline resistant *S aureus*(24). Bacillus species were isolated from both hospitals, Bacillus is capable of causing disease as it may be transferred into the body by dust and cause the disease known as (building related illness)(17). In addition to the isolation of certain *Pseudomonas* species from the drainage tanks and it is known that this bacteria is resistant to a variety of antibacterial agents and it is a major causative agent in nosocomial infections.

The results of this study have proved the use of air conditioners units in our buildings is a source of bacterial contamination and subsequently source of infection. To avoid the risk of dangerous infections a great care should be used to reduce this risk.

مكثفات الهواء مصدر للتلوث الجرثومي للبيئة الداخلية للمستشفيات

هند محمد خلف الله¹, عمر محمد أبوخريص*², علي فرج هواد¹, إبراهيم السنوسي مختار³ و حسين احمد الرشيد⁴

1قسم المختبرات الطبية، كلية العلوم الهندسية والتقنية، جامعة سبها، براك الشاطئ، ليبيا، 2. كلية طب الأسنان جامعة الجبل الغربي، غريان، ليبيا، 3. قسم الصحة العامة، كلية التقنية الطبية، جامعة طرابلس، طرابلس، ليبيا، 4-كلية الطب جامعة سبها*جميع المراسلات: عمر محمد أبوخريص، كلية طب الأسنان جامعة الجبل الغربي، غريان، ليبيا

المخلص

تهدف هذه الدراسات ألي تقييم المحتوي الجرثومي للتكييف والهواء الداخلي في بعض المستشفيات في جنوب ليبيا. أجريت هذه الدراسة في مستشفى 2 مارس بسبها و مستشفى براك العام. جُمعت العينات من الهواء الداخلي، ومن مرشحات وملفات المكثفات وأحواض صرف مياه المكثفات. زرعت العينات على أوساط blood agar و Mc conkey agar تم التعرف و عد ودراسة خصائص المستعمرات الجرثومية. شكلت الأعداد الجرثومية للعينات التي أخذت من الهواء الداخلي من مستشفى 2 مارس 56.57 % من العينات الكلية للبيئات الداخلية للمستشفيات، 79.9 % من عينات المرشحات الكلية، 72.07 % من عينات الملفات الكلية، و 54.63 % من عينات أحواض صرف المياه الكلية. الأعداد الجرثومية في العينات التي أخذت من مستشفى براك العام احتوت على 43.43 % من عينات الهواء الداخلي الكلية، 20.1 % من عينات المرشح الكلية، 27.93 % من عينات الملفات الكلية و 45.37 % من عينات أحواض صرف المياه الكلية.

البكتيريا الانحلالية كانت موجودة بأعداد قليلة علي وسط blood agar من البكتيريا غير الانحلالية، البكتيريا الغير تخميره موجودة بنسبة أقل من البكتيريا التخمرية على وسط Mc conkey agar. أنواع البكتيريا التي تم التعرف عليها تحتوي علي بعض أنواع البكتيريا المسببة للمرض مثل، S.aureus الموجودة في العينات المختلفة وكذلك Bacillus و K.pneumoniae و Pseudomonas هذه الأنواع متضمنة في الإصابات الخاصة بالمستشفيات .

الخلاصة: وجود الأعداد العالية من الجراثيم علي الأجزاء المختلفة من المكثفات ربما يليه انتشارها إلى البيئة الداخلية الأمر الذي يشكل خطر علي صحة الناس خصوصا بيئة المستشفيات حيث وجد مرضى بالإصابات المختلفة.

Reference

1. Chkrapan, P.P.E.(2008). Airborne infection Control for hospitals. Environminal Engineering Consultants. Co., Ltd. Bankok, Tailand.
2. Al-shahwani, M.F.(2005). Bacterial distribution analysis of the atmosphere of two hospitals in ibb, Yemen. *Eastern Mediterranean Health journal*.11: 1105-1106.
3. Mori, S.(2006).[Questions and answer on PET facilities: part 4]. *Nippon Hoshasen GijutsuGakkaiZasshi*. 26: 1653-1656.
4. Khurana, A.(2003): Ozone treatment for prevention of microbial growth in air conditioning systems. Thesis (M.Sc). University of florida.
5. Mendell, M.J. and Smith, A.H.(1990). Consistent Pattren of Elevated symptoms in Air-conditioned office Buidings: a reanalysis of epidemiologic studies. *American journal of public Health*. 80: 1193-1199.
6. Wong, L.T. (2008). Thermal Environmental interference with Airborne Bacteria and Fungi levels in Air-conditioned offices. *Indoor and Built Environment*. 17: 122-127.
7. Charkowska, A. (2003). The sound Attenuator-Source of Contamination in Air-

- conditioning systems. *International journal of ventilation*. 2:15-22.
8. **Linda, J.U., Kenneth, W. and Allan, H.F. (2003).** Minimizing pathogenic bacteria in indoor air. *Journal of Environmental Health*. 66:9-14
 9. **Tikhomirov, E. (1987).** WHO programme for control of hospital infection . *Chemiotherapia*. 6: 148-151.
 10. **Emori. T. G. And Gaynes, R. P. (1993).** An overview of nosocomial infection, including the role of the clinical laboratory. *Clinical Microbiology Reviews*. 6: 428-442.
 11. **Ross, C., de Menezes, J.R., Svidzinski, T.L., Albino, U. And Andrade, G. (2004).** Studies on Fungal and bacterial population of air-conditioned environments. *Brazilian Arshives of Biology and Technology*. 47:827-835.
 12. **Qudiesat, K ., Abu-Elkarmi, A., Hamad, M. And Abussaud, M. (2009).** Assessment of airborne pathogens in healthcare settings. *African journal of Microbiology Research*. 3: 66-76.
 13. **Sudharsanam, S., Srikanth,P ., Sheela, M. And Steinberg, R. (2008).** Study of the indoor Air Quality in Hospitals in South Chennai, india-Microbial Profile. *Indoor and Built Environment*. 17:435-441.
 14. **Bouillard, L., Michel, O., Dramaix, M. and Devleeschouzer, A (2005).** Bacterial Contamination of indoor air, suefaces, and settled dust, and related dust endotoxin concentrations in healthy office buildings. *Annals Agricultural & Environmental Medicine*. 21: 187-192.
 15. **Martin, M., Hans, P., Bettina, N. And Henning, R. (2001).** Capability of air filters to retain airborne bacteria and molds in heating, ventilating and air-conditioning (HVAC) systems. *International journal of hygien and environmental health*. 203: 401-409.
 16. **Hugenholtz, P. And Furest, J. (1992).** Heterotrophic Bacteria in Air-Handling System. *Applied and Environmental Microbiology*. 58: 3914-3920.
 17. **Yontz, R.R. (2003).** An overview of indoor air quality. Thesis (M.Sc). University of Mississippi state.
 18. **LeChevallier, M. (1988).** Factors Proving Survival of Bacteria in Chlorinated water Supplies. *Applied and Environmental Microbiology*. 54: 649-654.
 19. **Anwar, H. (1989).** Interaction of Biofilm Bacteria with Antibiotics in a Novel in vitro Chemostat System. *Antimicrobial Agents and Chemotherapy*. 54: 649-654.
 20. **Shin, H., and Frank, J. (1991).** Inactivation of Surface Adherent Listeria monocyto genes. Hypochlorite and heat . *journal of food protection*. 54: 4-6.
 21. **Hirvonen, M.R., Huttunen, K., and Roponen, M. (2005).** Bactrial strains from mold buildings are highly potint inducer of inflammatory and cytooxic effects. *Indoor Air*. 15: 65-70.
 22. **Liu, S.L.J. Krahmer, M. Fox, A., Feigley, C.E., Featherstone, A., Saraf A. and Larsson, L. (2000).** Investigation of the concentration of bacteria and Their cell Envelope Components in indoor Air in Two Elementary Schools. *Journal of the Air & waste Management Association*. 50: 1957-1967.
 23. **Nguyen, Q.V. (2009).** Hospital- Acquired infections. eMedicine. Available from: <http://www.emedicin.medscap.com>. [Accessed 3 Apri 2008]

24. Daum, R.S. (2008). Removing the Golden
Cost of Staphylococcus aureus. The New

England journal of Mfdicine. 359: 85-87.